


Drawing Alteration
The following is an excerpt from the
New York State Education Law Article
145 Section 7209 and applies to this


drawing: "It is a violation of this law for any "It is a violation of this law for any person, unless he is acting under the direction of a licensed professional engineer or land surveyor to alter any item in any way. If an item bearing the seal of an engineer or land surveyor is altered, the altering engineer or land surveyor shall affix to the item his seal and the notation "altered by" followed by his signature and the date of such alteration, and a specific description of the alteration."


SENCY COMMENTS	1/17/20	
COMMENTS	8/1/16	
NNING AND AGENCY COMMENTS	5/26/16	
NNING CONDITIONS OF APPROVAL	2/24/16	
NING COMMENTS	12/18/15	
DEMOIONS	DATE.	



DATE ISSUED







COPYRIGHT © 2021 **BME Associates**

PROJECT COBBS HILL PARK

> LOCATION MAP NOT TO SCALE


Drawing Alteration The following is an excerpt from the New York State Education Law Article 145 Section 7209 and applies to this "It is a violation of this law for any person, unless he is acting under the direction of a licensed professional engineer or land surveyor to alter any item in any way. If an item bearing the seal of an engineer or land surveyor is altered, the altering engineer or land surveyor shall affix to the item his seal

by his signature and the date of such

alteration, and a specific description of the alteration."

S

PROJECT MANAGER PROJECT ENGINEER DRAWN BY SCALE DATE ISSUED AUGUST, 2015 PROJECT NO.



Drawing Alteration The following is an except from the New York State Education Law Article 145 Section 7209 and applies to this

drawing: "It is a violation of this law for any person, unless he is acting under the direction of a licensed professional engineer or land surveyor to alter any item in any way. If an item bearing the seal of an engineer or land surveyor is altered, the altering engineer or land surveyor shall affix to the item his seal and the notation "altered by" followed by his signature and the date of such alteration, and a specific description of the alteration."


S


ANDSCAPE

PROJECT MANAGER

P. VARS PROJECT ENGINEER DRAWN BY R. GLITCH DATE ISSUED

DRAWING NO.





SUBBASE

ຸຸຄິ

CONCRETE CURB SECTION

MATERIAL -


SUBBASE


4000 PSI CONCRETE (PAINT


4000 PSI CONCRETE

SET POST IN-


COPYRIGHT © 2020























ARMORY

SHEET

Drawing Alteration

The following is an excerpt from the New York State Education Law Article

person, unless he is acting under the direction of a licensed professional

engineer or land surveyor to alter any item in any way. If an item bearing th


seal of an engineer or land surveyor is altered, the altering engineer or land surveyor shall affix to the item his seal


and the notation "altered by" followed by his signature and the date of such

alteration, and a specific description of the alteration."


S


145 Section 7209 and applies to this





NOTE: WHERE INLET AND OUTLET PIPES ARE OF DIFFERENT DIAMETERS THE SLOPE MUST NOT BE LESS THAN THE DIFFERENCE IN DIAMETER OR GREATER THAN 9" STORM & SANITARY MANHOLE DETAILS





BEDDING DETAILS

AND MECHANICAL PIPE/JOINT

WATER MAIN -

45° BEND—

SEE NOTES 3 AND 4

STANDARD LENGTH OF

WATER MAIN PIPE -

SEE NOTE 1

SECTION OF

- WATER MAIN PIPE


TO BE RELOCATED


RESTRAINT - SEE NOTE 2


COMPACTED SELECT


- GRANULAR BACKFILL

SEWER PIPE









ON PLASTIC WATER MAINS SHALL BE COATED WITH CITY OF ROCHESTER PREPACKAGED CLOTH BAG WITH BACKFILL. WEIGHT OF ANDDE INGOT (EXCLUDING BACKFILL) AND SPACING OF ANODE AT NEW DUCTILE ANDDES ALONG DUCTILE IRON WATER MAIN AS NOTED

ANDDE IS TO BE PLACED IN TRENCH WITH ANDDE CENTERLINE 6 INCHES MINIMUM BELOW BOTTOM OF PIPE OR FITTING AND 2 FEET MINIMUM FROM SIDE WALL OF PIPE OR FITTING. ANODE TO BE SURROUNDED WITH NATIVE BACKFILL

2. USE HIGH POTENTIAL MAGNESIUM ANODE IN

ON PLANS OR AS DIRECTED BY PROJECT MANAGER.

4. FACTORY CAST OFFSETS ARE TO BE TREATED AS (2)

FOR REDUCERS, THRUST BLOCK IS TO BE KEYED INTO

MECHANICAL RESTRAINT IS REQUIRED IN ADDITION TO

45 DEGREE BENDS.

WALLS AND BOTTOM OF TRENCH.

THRUST BLOCK, SEE DETAIL \$900-7.

WOOD BLOCKING IS NOT PERMITTED.

PRIMER AND WAX TAPE.

EXISTING SURFACE


AT TIME OF WATER

PIPE INSTALLATION

IRON WATER MAIN OR DUCTILE IRON FITTING ON NEW PLASTIC WATER MAIN

THRUST BLOCK

ISSUED 3-21-02 NON-STANDARD REMSED 12-28-10 DWG.NO.S966-1



CITY OF ROCHESTER

WATER MAIN

CROSSING BELOW

SEWER PIPE

ISSUED 1-13-06 NON-STANDARD


REVISED 11-22-10 DWG.NO.S900-3


ONE STANDARD FULL LENGTH OF WATER MAIN PIPE IS TO BE CENTERED ON SEWER PIPE SO THAT BOTH JOINTS OF WATER MAIN PIPE WILL BE AS FAR FROM SEWER PIPE AS

SEE NOTE 5

SAND BACKFILL

- THRUST BLOCKS AND PIPE/JOINT RESTRAINTS ARE TO BE PROVIDED AT ALL BENDS, SEE DETAILS \$900-5, \$900-7, \$900-8
- WHERE WATER MAIN PIPE PASSES UNDER SEWER PIPE THERE IS TO BE MINIMUM 18 INCHES OF VERTICAL SEPARATION BETWEEN WATER MAIN PIPE AND SEWER PIPE.
- WHERE VERTICAL SEPARATION IS LESS THAN 18 INCHES, WATER MAIN PIPE JOINTS LOCATED WITHIN 18 FEET OF BOTH SIDES OF SEWER PIPE MUST BE ENCASED WITHIN CONTROLLED DENSITY FILL MATERIAL, OR SEWER PIPE CONSTRUCTED WITH WATER MAIN STANDARD PIPE AND TESTED TO 150 PSI.
 - WHERE WATER MAIN PIPE PASSES UNDER SEWER PIPE THERE IS TO BE MINIMUM OF 6 INCHES OF CLASS K CONCRETE OR CRUSHED STONE BEDDING MATERIAL FOR SEWER PIPE.





PROJECT MANAGER P. VARS PROJECT ENGINEER DRAWN BY R. GLITCH SCALE DATE ISSUED 1"=50' AUGUST, 2015 PROJECT NO. DOMESTIC SYSTEM DRAWING NO. 1-13-06 NON-STANDARD REVISED 8-7-13 DWG.NO.S900-4 (SHEET 2 OF 5)

S

Drawing Alteration

The following is an excerpt from the New York State Education Law Article

person, unless he is acting under the direction of a licensed professional

engineer or land surveyor to alter any item in any way. If an item bearing th

seal of an engineer or land surveyor is altered, the altering engineer or land surveyor shall affix to the item his seal

by his signature and the date of such

alteration, and a specific description of the alteration."

145 Section 7209 and applies to this


This plan is subject to revisions until all approvals are obtained and should not be used for construction


NOT APPROVED


This plan has not received final

approval of all reviewing agencies

COPYRIGHT © 2020








THE CONTRACTOR SHALL MAKE AND SHORE THE EXCAVATION, CLEAN TH AREA OF THE WATER MAIN FOR THE TAP, ATTACH THE TAPPING SLEEVE AND VALVE TO THE MAIN FOR SERVICES 4-INCH DIAMETER AND LARGER OR ATTACH THE TAPPING SADDLE (WHERE REQUIRED) TO THE MAIN FOR SERVICES 2-INCH DIAMETER AND SMALLER AND INSURE THAT THE WORK AREA IS READY FOR INSPECTION BY BUREAU PERSONNEL PRIOR TO MAKING THE TAP.

WATER SERVICE TAP **EXCAVATION**

4-29-11 NON-STANDARD DWG.NO.S900-12



1. LOCATION OF SAMPLING TAPS ARE SUBJECT TO PRIOR APPROVAL BY CITY AND MONROE COUNTY DEPARTMENT OF PUBLIC HEALTH.

2. IF SAMPLING TAP IS LOCATED IN PAVED AREA, SAMPLING TAP IS TO BE KEPT BELOW GROUND EXCEPT WHEN IN USE.

3. IF APPROVED BY CITY, SAMPLING TAP MAY BE LOCATED AT SAME LOCATION AS NEW WATER

4. IF SAMPLING TAP IS NOT TO BE USED AS NEW WATER SERVICE, UPON NOTIFICATION OF ACCEPTABLE SAMPLE RESULTS, CORPORATION STOP IS TO BE REMOVED AND REPLACED WITH A BRASS PLUG OR CORPORATION STOP IS TO BE CLOSED, SERVICE PIPE DISCONNECTED FROM CORPORATION AND BRASS CAP INSTALLED ON OUTLET OF CORPORATION STOP.

5. MAXIMUM DISTANCE BETWEEN SAMPLING TAPS ON NEW WATER MAIN INSTALLATION IS 1,000 FEET.

CITY OF ROCHESTER DISINFECTION SAMPLING TAP

1-13-06 NON-STANDARD

INSTRUCTIONS.

REVISED 2-19-15 DWG.NO.S900-6

WATER SERVICE TRACER WIRE - STRIP INSULATION TO WIDTH OF LUG ONLY PLASTIC HOUSING - WITH METALLIC LUG AND SEALANT PLAN SET SCREW — -METALLIC LUG WATER SERVICE WATER MAIN TRACER WIRE SECTION OF LUG LUG STYLE WATER SERVICE TRACER WIRE WRAP SPLIT BOLT CONNECTOR AND STRIP INSULATION TO WIDTH OF EXPOSED TRACER WIRES WITH 3 LUG ONLY SUCCESSIVE LAYERS EACH OF RUBBER SPLICING AND VINYL TAPES WATER MAIN TRACER WIRE -STRIP INSULATION TO WIDTH OF BRONZE ALLOY SPLIT BOLT LUG ONLY - DO NOT CUT TRACER CONNECTOR PROPERLY SIZED FOR WATER MAIN TRACER WIRE AND #12 SOLID TAP SPLIT BOLT STYLE CITY OF ROCHESTER PLASTIC WATER

SET SCREW —

SERVICE TAP SPLICE CONNECTION IS TO BE USED FOR CONNECTING WATER SERVICE TRACER WIRE TO WATER MAIN TRACER WIRE WITH

TRACER WIRE TAP SPLICE CONNECTION 6-1-09 NON-STANDARD CONNECTION BEING MADE IN ACCORDANCE WITH MANUFACTURER'S **ISSUED** DWG.NO.S901-11

ON EXISTING

WATER MAIN

REVISED


WATER MAIN TRACER WIRE -

STRIP INSULATION TO WIDTH OF LUG

ONLY - DO NOT CUT TRACER WIRE

8-8-11 NON-STANDARD

DWG.NO.S970-4



5970-8.

2. FOR CLASS 4 AND 5 FIRE SYSTEMS OR WHEN SERVICE IS LOCATED WITHIN 1,700 FEET OF HOLLY SYSTEM OR RIVER, FURNISH WITH REDUCED PRESSURE DETECTOR ASSEMBLY (RPDA).

3. GATE VALVES SHALL BE OS&Y RISING STEM, RESILIENT SEATED, FLANGED END, OPEN LEFT AND SHALL BE UL/FM

5. BYPASS PIPING ON DCDA AND RPDA SHALL BE 3/4 INCH COPPER OR BRASS. BYPASS FITTINGSAND VALVES SHALL BE BRASS.

AND INSTALLED BY THE PLUMBER. COUPLINGS ARE AVAILABLE FOR PICK UP AT THE WATER BUREAU OPERATIONS CENTER, 10 FELIX

CITY OF ROCHESTER

SERVICE

8-8-11 NON-STANDARD |REVISED 3-8-12|DWG.NO.S970-9

	TO BACKFLOW PREVENTER, IF REQUIRED. (SEE DETAIL S971-1)
	SEE DETAIL S970-2 FOR METER SIZES 1" AND SMALLER OR DETAIL S970-3 FOR METER SIZES 1½" AND 2 " BALL VALVE DOMESTIC METER APPROVED BY BUREAU
BUILDING WALL	STRAINER (1½" AND 2" METERS ONLY) BALL VALVE ON 1½" AND 2" METERS SEE NOTES 1 AND 2 AND DETAIL S970-8
SERVICE PIPE RESTRAINED FROM WATER MAIN (SEE DETAIL S970-4)	SOLID FLANGED END PIPE (TYPICAL) DOUBLE CHECK DETECTOR ASSEMBLY (DCDA) OR REDUCED PRESSURE DETECTOR ASSEMBLY (RPDA)
FLOW -	
PIPE SLEEVE AND SEAL	RISING STEM RESILIENT SEAT VALVE GATE VALVE - OPEN LEFT (TYPICAL) BALL VALVE DOUBLE CHECK VALVE
NOTES:	PLAN PLAN
1. FOR CLASS 1, 2 AND 3 FIF S970-8.	RE SYSTEMS, FURNISH WITH DOUBLE CHECK DETECTOR ASSEMBLY (DCDA) PER DETAIL

4. DCDA AND RPDA SHALL HAVE AN EPOXY COATED CAST OR DUCTILE IRON BODY, FLANGED ENDS, BE UL/FM APPROVED AND APPROVED BY THE FOUNDATION FOR CROSS-CONNECTION CONTROL AND HYDRAULIC RESEARCH AT THE UNIVERSITY OF SOUTHERN CALIFORNIA. DCDA AND RPDA SHALL HAVE TRIM KIT FOR BY-PASS METER AND APPURTENANCES.

6. BYPASS METER COUPLINGS ARE FURNISHED BY THE WATER BUREAU STREET, TELEPHONE 428-7618.

8. PIPE AND APPURTENANCES ARE TO BE ADEQUATELY RESTRAINED,

CONFORMANCE WITH APPLICABLE FEDERAL, STATE AND LOCAL

PLUMBING CODES.

BRACED AND SUPPORTED. ALL WORK AND MATERIALS SHALL BE IN

TYPICAL COMBINATION 7. THE WATER BUREAU WILL FURNISH, INSTALL AND SEAL THE BYPASS METER, SEAL THE BY-PASS BALL VALVES AND INSTALL A FIRE AND DOMESTIC REMOTE TOUCH PAD OR RADIO READING DEVICE.

seal of an engineer or land surveyor is altered, the altering engineer or land surveyor shall affix to the item his seal by his signature and the date of such alteration, and a specific description of the alteration."

Drawing Alteration The following is an excerpt from the New York State Education Law Article 145 Section 7209 and applies to this

person, unless he is acting under the direction of a licensed professional

engineer or land surveyor to alter any item in any way. If an item bearing th

ARMOR


PROJECT MANAGER PROJECT ENGINEER DRAWN BY SCALE DATE ISSUED

PROJECT NO.

DRAWING NO.

COPYRIGHT © 2020

(SHEET 3 OF 5)



_4" TOP CAP

[∠]6" BASE

LEVELING

COURSE

2+50

TOP OF WALL=509.0

└6" BASE

LEVELING

COURSE

NOTE: FUTURE RETAINING WALL IS TO BE


PARKING IS INSTALLED

CONSTRUCTED WHEN LAND BANKED

FUTURE RETAINING WALL

SCALE 1"=50' HORIZONTAL

1"=5' VERTICAL



PLASTIC WATER MAIN

TRACER WIRE

INSTALLATION

1-13-06 NON-STANDARD

₆₋₁₋₀₉ DWG.NO.S901-8

WATER VALVE, TRACER WIRE IS TO RUN ALONG SIDE OF PLASTIC

TRACER WIRE IS TO BE CONNECTED TO TERMINATION BOX


INSTALLED ADJACENT TO HYDRANT. EXTEND TRACER WIRE UP


TRACER WIRE COILED UP INSIDE TOP OF TERMINATION BOX.


CONNECT END OF TRACER WIRE TO TERMINAL BOARD.


INSIDE OF TERMINATION BOX LEAVING MINIMUM OF 3 FEET OF


WATER MAIN PIPE.




















- CRUSHED STONE

LEVELING PAD

(AS SPECIFIED BY

ENGINEER)

NOTES:

1. INSTALLATION TO BE COMPLETED IN ACCORDANCE WITH

MANUFACTURER'S SPECIFICATIONS. 2. ALL DIMENSIONS ARE CONSIDERED TRUE AND REFLECT MANUFACTURER'S SPECIFICATIONS.

DO NOT SCALE DRAWING. THESE DRAWINGS ARE NOT FOR CONSTRUCTION PURPOSES AND ARE FOR INFORMATION PURPOSES ONLY. ALL INFORMATION CONTAINED HEREIN WAS CURRENT AT THE TIME OF DEVELOPMENT BUT MUST BE REVIEWED AND APPROVED BY THE PRODUCT MANUFACTURER TO BE CONSIDERED ACCURATE.


CONTRACTOR'S NOTE: FOR PRODUCT AND COMPANY INFORMATION VISIT www.CADdetails.com/info REFERENCE NUMBER 438-232.

> NOTE: FUTURE RETAINING WALL IS TO BE CONSTRUCTED WHEN LAND BANKED PARKING IS INSTALLED

The following is an excerpt from the New York State Education Law Article 145 Section 7209 and applies to this drawing:
"It is a violation of this law for any person, unless he is acting under the direction of a licensed professional engineer or land surveyor to alter any item in any way. If an item bearing the seal of an engineer or land surveyor is altered, the altering engineer or land surveyor shall affix to the item his seal and the notation "altered by" followed by his signature and the date of such alteration, and a specific description of the alteration."

Drawing Alteration

S



ARMORY ROAD CULVER

PROJECT MANAGER P. VARS PROJECT ENGINEER J. CRETEKOS DRAWN BY R. GLITCH SCALE DATE ISSUED 1"=50' AUGUST, 2015


PROJECT NO.

DRAWING NO.

(SHEET 4 OF 5)

COPYRIGHT © 2020

DATUM ELEV 490.00



3. ANDDE IS TO BE PLACED IN TRENCH, WITH ANDDE

4. WHEN TWO ANDDES ARE REQUIRED AT NEW WATER

SERVICE, THE SECOND ANDDE SHALL BE LOCATED ON

OPPOSITE SIDE OF WATER MAIN, SECOND ANODE LEAD


MAIN AT LEAST 1 FOOT FROM THERMITE WELD FOR

WIRE SHALL BE THERMITE WELDED TO TOP OF WATER


TO BE SURROUNDED WITH NATIVE BACKFILL


FIRST ANDDE LEAD WIRE.

CENTERLINE 6 INCHES MINIMUM BELOW BOTTOM OF MAIN



WATER MAIN ISSUED 11-26-08 NON-STANDARD REVISED 12-28-10 DWG.NO.S966-4





CAST/ DUCTILE IRON WATER

7-7-16 NON-STANDARD

DWG.NO.S966-9

1. IF DIMENSION "A" BETWEEN THE CENTERLINE OF THE WATER MAIN AND THE FACE OF CURB IS 6 FEET OR LESS, THE CURB VALVE IS NOT REQUIRED. CURB VALVE IS REQUIRED WHEN DIMENSION "A" EXCEEDS 6 FEET.

2. A METER VAULT MAY BE REQUIRED FOR A DOMESTIC SERVICE, WHEN THE WATER SERVICE LENGTH, AS MEASURED FROM THE STREET RIGHT-OF-WAY LINE TO THE BUILDING WALL, EXCEEDS 100 FEET. WHEN THE WATER SERVICE LENGTH EXCEEDS 100 FEET, THE WATER BUREAU WILL REVIEW EACH NEW WATER SERVICE PLAN TO DETERMINE IF THE METER SHOULD EITHER BE PLACED; INSIDE OF THE HEATED BUILDING; IN A METER VAULT DUTSIDE OF THE BUILDING NEAR THE RIGHT-OF-WAY LINE OR IN A HEATED ABOVE GROUND ENCLOSURE NEAR THE RIGHT-OF-WAY LINE.

3. ALL JOINTS ON NEW WATER SERVICE PIPE, FITTINGS AND VALVES SHALL BE MECHANICALLY RESTRAINED. CONCRETE THRUST BLOCKS ARE ALSO REQUIRED AT FITTINGS PER DETAIL DRAWINGS \$900-4, \$900-5, \$900-9 AND \$900-10.

4. A BACKFLOW PREVENTION DEVICE IS REQUIRED ON ALL DOMESTIC WATER SERVICES 11/2


5. NEW WATER SERVICE SHALL BE PRESSURE TESTED FROM GUARD VALVE TO WITHIN 5 FEET OF EXTERIOR BUILDING WALL, PRESSURE TESTING SHALL BE PERFORMED IN ACCORDANCE WITH SPECIFICATION \$900-3.05. PIPE, FITTING AND VALVE JOINTS ON PORTION OF SERVICE NOT SUBJECT TO PRESSURE TEST SHALL BE LEAK TESTED AT NORMAL OPERATING PRESSURE.

6. WHEN THE LENGTH OF THE NEW WATER SERVICE EXCEEDS 50 FEET, WATER SERVICE SHALL BE DISINFECTED USING THE CONTINUOUS FEED METHOD IN ACCORDANCE WITH SPECIFICATION S900-3.06. FOR WATER SERVICES LESS THAN 50 FEET, ALL WATER SERVICE PIPE, FITTINGS AND VALVES SHALL BE SPRAY OR SWAB DISINFECTED WITH 1%-5% CHLORINE

7. ON PLASTIC WATER SERVICES, WHEN DIMENSION "A" IS 6 FEET OR LESS AND THE CURB VALVE IS NOT REQUIRED, EXTEND TRACER WIRE ALONG SERVICE TO RIGHT-OF-WAY LINE AND INSTALL TRACER WIRE TERMINATION BOX AT RIGHT-OF-WAY.

8. ONE MAGNESIUM ANODE IS TO BE INSTALLED ON EACH PIECE OF NEW DUCTILE IRON WATER SERVICE PIPE BETWEEN THE WATER MAIN AND RIGHT-OF-WAY LINE. SEE DETAIL \$966-2. USE 17 POUND ANDDE ON 4 INCH AND 6 INCH PIPE, 32 POUND ANDDE ON 8 INCH AND 10 INCH PIPE AND 48 POUND ANODE ON 12 INCH PIPE.

9. ALL DUCTILE IRON WATER SERVICE PIPE, FITTINGS AND VALVES LOCATED WITHIN THE STREET RIGHT-OF-WAY ARE TO BE INSTALLED IN POLYETHYLENE ENCASEMENT.




CENTERLINE 6 INCHES MINIMUM BELOW BOTTOM OF MAIN SLEEVE AND CUT-IN TEE

3. ALL NEW DUCTILE IRON PIPE NIPPLES AND FITTINGS ISSUED 1-05-12 NON-STANDARD

ON EXISTING IRON PIPE

DWG.NO.S966-




MAIN AND 2 FEET MINIMUM FROM SIDE WALL OF MAIN.

ANDDE TO BE SURROUNDED WITH NATIVE BACKFILL.

3. WHEN TWO ANDDES ARE REQUIRED AT NEW WATER


SERVICE, THE SECOND ANDDE SHALL BE LOCATED ON

OPPOSITE SIDE OF THE TAPPING SLEEVE AND VALVE.



HAMMER AFTER WELD HAS COOLED. AVOID

STRIKING WIRE.




2. ANODE IS TO BE PLACED IN TRENCH, WITH ANODE

AND 2 FEET MINIMUM FROM SIDE WALL OF MAIN. ANODE

TO BE SURROUNDED WITH NATIVE BACKFILL.

ARE TO BE ENCASED WITH POLYETHYLENE WRAP



PROJECT MANAGER PROJECT ENGINEER DRAWN BY R. GLITCH

REVISED 12-28-10 DWG.NO.S966-2

SCALE DATE ISSUED 1"=50' AUGUST, 2015 PROJECT NO. ISSUED 10-17-08 NON-STANDARD

DRAWING NO.

(SHEET 5 OF 5)

P. VARS

J. CRETEKOS

TE OF NEW

The following is an excerpt from the New York State Education Law Article 145 Section 7209 and applies to this

person, unless he is acting under the direction of a licensed professional engineer or land surveyor to alter any item in any way. If an item bearing the

seal of an engineer or land surveyor is altered, the altering engineer or land surveyor shall affix to the item his seal

by his signature and the date of such

alteration, and a specific description of the alteration."

COPYRIGHT © 2020

